Nalanda University, Rajgir, District Nalanda, University
Pin 803 116, Bihar, India T+91 611 2255 330 www.nalandauniv.edu.in



No.NU/Interim Camp/

То		

Sub: Limited Tender Enquiry is invited for Quotation of providing and installing 7.5 KVA Online UPS for SEES lab at Interim Campus of Nalanda University.

Dear Sir(s),

1. Sealed quotations (Double bid) are invited for providing and installing 7.5 KVA Online UPS (Single Phase) for SEES lab at Nalanda University, as per Specifications detailed in Annexed Price Schedule and on the terms & conditions as detailed hereunder:-

2. DUE DATE & TIME FOR RECEIPT/OPENING OF QUOTATION:-

- (i) Last date and time to submit Bid Document: 02.08.2016 (Tuesday)up to 3.00 pm
- (ii) Due date and time for opening of Bid: 02.08.2016 (Tuesday) at 3.30 pm at University Campus, Nalanda University, Rajgir.

3. MODE OF SUBMISSION OF QUOTATION:-

The quotation may be sent by post or may be dropped in the Tender Box of the Nalanda University, Rajgir, placed in the office of Administration on or before due date & time of receipt of offer as indicated above. Quotation which do not reach this office latest by 3:00 PM on the due date, will not be opened and will be retained in the office. The Nalanda University will not be responsible for any delay in receipt of quotation by post what so ever may be the reason.

4. VALIDITY:-

The offer shall be kept valid for a period of 90 days (Ninety days) from the date of opening of Technical Bid.

5. **PRICES**:-

The prices shall be for providing and fixing of 7.5 KVA Online UPS (Single Phase) for SEES lab at Nalanda University, Rajgir, District Nalanda, On door delivery basis inclusive of packing, freight & forwarding charges, Excise Duty, VAT/CST/BRCT & other levies, if any. Payment of any types of Govt. Statutory levies/taxes will be responsibility of the bidders. Please ensure that the rates/prices are strictly filled in the Schedule-I enclosed herewith.





<u>Earnest Money Deposit</u>: Rs. 12,500/- (Rupees Twelve thousand Five only) drawn in favour of Nalanda University payable at Rajgir is to be submitted as EMD.

Details of the Earnest Money Deposit (EMD):-

Sr. No.	DD No./Banker's Cheque	Date	Amount (Rs.)	Drawn on Bank

<u>Tender Fee</u>: - A demand draft/Banker's Cheque amounting to Rs.500/- drawn at a nationalized bank in favour of "Nalanda University payable at Rajgir" is to be submitted as Tender fees.)

6. PROVIDING & FIXING of CONSIGNMENT:-

The delivery within stipulated time period (30 Days) will be the essence of the contract as per issuance of work order and has to be strictly adhered to by the bidder. There shall not be any compromise in the quality of goods delivered and scheduled delivery under any circumstances.

7. **PAYMENT**:-

Subject to completion of all formalities as per terms of order in following manner:

- 90% payment of each consignment inclusive of all charges shall be paid to the firms within 30 days from the date of fixing of equipment in good condition.
- ii) The payment shall be released by the Finance section (Bills), Nalanda University, Rajgir, District Nalanda on submission of the triplicate copy invoice in original.
- iii) 10 % payment shall be released after successful completion of 3 months and satisfactory certificates provided by users/Engineering section.
- 8. **PENALTY:-**The delivery period is the essence of the contract and has to be maintained under any circumstances In case of delay in execution of the order, the Nalanda University may at its option either:-
 - (i) Recover from the supplier/vendor as agreed towards liquidated damages a sum $@ \frac{1}{2}\%$ (half percent) of the price of any stores not delivered for a week or part thereof subject to maximum of 10%.

OR

(iii) Purchase from elsewhere on account and at the risk and responsibility of the suppliers, the stores not delivered or others of similar descriptions.

OR

Nalanda University, Rajgir, District Nalanda, Pin 803 116, Bihar, India T+91 611 2255 330 www.nalandauniv.edu.in





(iii) Cancel the contract for part or whole of the quantity on order, with liability.

9. CONSIGNEE:-

The delivery of the item is to be made to the faculty In charge of SEES Lab, Nalanda University.

10. ACCEPTANCE:

It is not binding on the Purchaser to accept the lowest or any tender. The Nalanda University reserves their right to accept or reject any offer at its option or place order with more than one supplier for full or part of the quantity of this enquiry without assigning any reason and the same shall be binding on suppliers unless otherwise stated in the offer. No correspondence shall be entertained on this account.

11. **DISPUTES:**

All disputes, if any, out of or in respect to this enquiry are to be settled at court Rajgir District- Nalanda. Stated specifically to the contrary it shall be deemed that you have agreed to all terms and conditions mentioned in the enquiry and the same shall be binding on you.

Bidders/Suppliers are requested to confirm their acceptance to the commercial terms & conditions as per Enquiry. Stated specifically to the contrary it shall be deemed that you have agreed to all terms and conditions mentioned in the enquiry and the same shall be binding on you.

12. **Warranty Date: -** Minimum 2 Years or as per OEM whichever will be on later date.

Please acknowledge the receipt of enquiry.

Encl: - (1) Schedule-I (Price & Quantity Schedule) & Schedule II-(Technical Specification)

.

Yours faithfully

Registrar

Nalanda University, Rajgir District: Nalanda (Bihar)

SCHEDULE-I: **Price & Quantity** (To be kept in the sealed envelope)

SI.	Particulars for	Unit	Qty.	Per Unit	VAT@	Total
No	Providing and		_	Rate	(%)	(including
	fixing of following					VAT)



Nalanda University, Rajgir, District Nalanda, Pin 803 116, Bihar, India T+91 611 2255 330 www.nalandauniv.edu.in



	Grant Total Amount i	n words			
	Grant Total Amount ((Rs)			
03	Wire CU FRLS 10 Sq. mm	Meter	50		
02	BATTERY DETAILS: 75 Ah	Set	20		
01	7.5 KVA ONLINE UPS SYSTEM WITH 120 MIN BATTERY BACK UP TOGETHER WITH STAND AND CONNECTORS.	Set	01		

NOTE: Installation charge of the equipment will be borne by the agency.

- 01. Rates in various tapering steps shall not be considered
- The offers, with the rates given in any form/Performa, other than mentioned above may be liable for rejection.
- 03. Payment of any type of Govt. statutory levies/taxes will be responsibility of the Bidder.
- 04. While quoting the prices, Make and model of the offered material required to be indicated.
- 05. Warranty as per manufacturer or minimum 2 years whichever will be on later date.
- 06. Only reputed makes shall be considered.

Signature & Seal of Tenderer Name in full & Designation

SCHEDULE-II: Technical Specifications

(To be kept in the sealed envelope)

Item #		Specifications	Unit(s)



Nalanda University, Rajgir, District Nalanda, Pin 803 116, Bihar, India T+91 611 2255 330 www.nalandauniv.edu.in



7.5 kva UPS System with 120 mins Battery Backup together with stand and connectors, enclosures etc IP-21. UPS - Three in and Single out (Input 3-Q, O/P -1 Q) Short circuit current from inverter -1 ph. :- As per Standard Over Load capacity 200 % for 30 sec voltage distribution with linear load < 1 %. 1. Normal rating 7.5 KVA (As per IEC 60896 or equivalent IS/EN/BS) 2. Rectifier type : As per Standard 3. Input (i) Voltage as per standard applicable in Rajgir Locality (Generally 190 to 265 V). (ii) Frequency 50 HZ +/- 5% (47.5 to 52.5 HZ) (iii) PF 0.90 - 0.95 with optimized harmonic filter (iv) Frequency stability- As per standard. (v) Wave form- Pure sine wave- THDC < 2% Linear Load (vi) Audible Alarm- Main Failure, Low Battery, Over Load (vii) Output- 230 V, 50 HZ, 1-Q (viii) The psophometric Noise and ripple shall be as per relevant standard. D2 Battery Details: 75 Ah x 20 nos. Battery shall be sized at an average temperature of 27 degree C (0 to 45 degree) Battery Make: : Exide or equivalent, each cell 12 watt SMF/Lead Acid/Tubular Mire CU FRLS 10 Sq. mm for connection			UNIVERSIT
UPS - Three in and Single out (Input 3-Q, O/P -1 Q) Short circuit current from inverter -1 ph. :- As per Standard Over Load capacity 200 % for 30 sec voltage distribution with linear load < 1 %. 1. Normal rating 7.5 KVA (As per IEC 60896 or equivalent IS/EN/BS) 2. Rectifier type : As per Standard 3. Input (i) Voltage as per standard applicable in Rajgir Locality (Generally 190 to 265 V). (ii) Frequency 50 HZ +/- 5% (47.5 to 52.5 HZ) (iii) PF 0.90 - 0.95 with optimized harmonic filter (iv) Frequency stability- As per standard. (v) Wave form- Pure sine wave- THDC < 2% Linear Load (vi) Audible Alarm- Main Failure, Low Battery, Over Load (vii) Output- 230 V, 50 HZ, 1-Q (viii) The psophometric Noise and ripple shall be as per relevant standard. Description of the standard of the	01	7.5 kva UPS System with 120 mins Battery	Set
Short circuit current from inverter -1 ph. :- As per Standard Over Load capacity 200 % for 30 sec voltage distribution with linear load < 1 %. 1. Normal rating 7.5 KVA (As per IEC 60896 or equivalent IS/EN/BS) 2. Rectifier type : As per Standard 3. Input (i) Voltage as per standard applicable in Rajgir Locality (Generally 190 to 265 V). (ii) Frequency 50 HZ +/- 5% (47.5 to 52.5 HZ) (iii) PF 0.90 - 0.95 with optimized harmonic filter (iv) Frequency stability- As per standard. (v) Wave form- Pure sine wave- THDC < 2% Linear Load (vi) Audible Alarm- Main Failure, Low Battery, Over Load (vii) Output- 230 V, 50 HZ, 1-Q (viii) The psophometric Noise and ripple shall be as per relevant standard. Description of the proposition of the propo		Backup together with stand and connectors, enclosures etc IP-21.	
Over Load capacity 200 % for 30 sec voltage distribution with linear load < 1 %. 1. Normal rating 7.5 KVA (As per IEC 60896 or equivalent IS/EN/BS) 2. Rectifier type: As per Standard 3. Input (i) Voltage as per standard applicable in Rajgir Locality (Generally 190 to 265 V). (ii) Frequency 50 HZ +/- 5% (47.5 to 52.5 HZ) (iii) PF 0.90 - 0.95 with optimized harmonic filter (iv) Frequency stability- As per standard. (v) Wave form- Pure sine wave- THDC < 2% Linear Load (vi) Audible Alarm- Main Failure, Low Battery, Over Load (vii) Output- 230 V, 50 HZ, 1-Q (viii) The psophometric Noise and ripple shall be as per relevant standard. 8et Battery Details: 75 Ah x 20 nos. Battery shall be sized at an average temperature of 27 degree C (0 to 45 degree) Battery Make: Exide or equivalent, each cell 12 watt SMF/Lead Acid/Tubular		UPS - Three in and Single out (Input 3-Q, O/P -1 Q)	
1. Normal rating 7.5 KVA (As per IEC 60896 or equivalent IS/EN/BS) 2. Rectifier type: As per Standard 3. Input (i) Voltage as per standard applicable in Rajgir Locality (Generally 190 to 265 V). (ii) Frequency 50 HZ +/- 5% (47.5 to 52.5 HZ) (iii) PF 0.90 - 0.95 with optimized harmonic filter (iv) Frequency stability- As per standard. (v) Wave form- Pure sine wave- THDC < 2% Linear Load (vi) Audible Alarm- Main Failure, Low Battery, Over Load (vii) Output- 230 V, 50 HZ, 1-Q (viii) The psophometric Noise and ripple shall be as per relevant standard. 8 Battery Details: 75 Ah x 20 nos. Battery shall be sized at an average temperature of 27 degree C (0 to 45 degree) Battery Make:: Exide or equivalent, each cell 12 watt SMF/Lead Acid/Tubular		Short circuit current from inverter -1 ph. :- As per Standard	
IS/EN/BS) 2. Rectifier type: As per Standard 3. Input (i) Voltage as per standard applicable in Rajgir Locality (Generally 190 to 265 V). (ii) Frequency 50 HZ +/- 5% (47.5 to 52.5 HZ) (iii) PF 0.90 - 0.95 with optimized harmonic filter (iv) Frequency stability- As per standard. (v) Wave form- Pure sine wave- THDC < 2% Linear Load (vi) Audible Alarm- Main Failure, Low Battery, Over Load (vii) Output- 230 V, 50 HZ, 1-Q (viii) The psophometric Noise and ripple shall be as per relevant standard. 8 Battery Details: 75 Ah x 20 nos. Battery shall be sized at an average temperature of 27 degree C (0 to 45 degree) Battery Make:: Exide or equivalent, each cell 12 watt SMF/Lead Acid/Tubular			
Battery shall be sized at an average temperature of 27 degree C (0 to 45 degree) Battery Make: : Exide or equivalent, each cell 12 watt SMF/Lead Acid/Tubular Wire CLIEBLS 10 Sq. mm for connection		IS/EN/BS) 2. Rectifier type: As per Standard 3. Input (i) Voltage as per standard applicable in Rajgir Locality (Generally 190 to 265 V). (ii) Frequency 50 HZ +/- 5% (47.5 to 52.5 HZ) (iii) PF 0.90 - 0.95 with optimized harmonic filter (iv) Frequency stability- As per standard. (v) Wave form- Pure sine wave- THDC < 2% Linear Load (vi) Audible Alarm- Main Failure, Low Battery, Over Load (vii) Output- 230 V, 50 HZ, 1-Q (viii) The psophometric Noise and ripple shall be as per relevant	
Wire CILERIS 10 Sq. mm for connection	02	Battery shall be sized at an average temperature of 27 degree C (0 to 45 degree)	Set
	03		Meter

We hereby accepting all the technical specification as stipulated in this enquiry.

Signature & Seal of Tenderer Name in full & Designation